

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
Mrs. Cintia Chagas de Oliveira
Hiltistraße 6
86916 Kaufering

Dear Mrs. Chagas de Oliveira,

based on the evaluation of Test Report No. 55493-A004 dated 2020-09-29, the testing results of the product **Hilti Firestop Coating CP 673** manufactured by **Hilti Entwicklungsgesellschaft mbH** comply with the requirements of

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.2-2017 (California Specification 01350 (01/2017))

These criteria meet the requirements for low-emitting **Adhesives and Sealants** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

| Exposure Scenario | Individual VOCs of Concern | | Formaldehyde | | TVOC |
|-------------------|----------------------------|------------------|--------------|------------------|-------------|
| | Requirement | Requirement hold | Requirement | Requirement hold | Range |
| School Classroom | ½ CREL | yes | ≤ 9 µg/m³ | yes | ≤ 0.5 mg/m³ |
| Private Office | ½ CREL | yes | ≤ 9 µg/m³ | yes | ≤ 0.5 mg/m³ |

Mass per surface area: 1450 g/m²

Cologne, 2020-11-12



Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project manager)