

## Pipe Hangers

Pipe hangers are used to support a sprinkler piping system from the building structure. Two or more listed components may be required to form a complete hanger. The specific components required depend upon the type of building construction and the pipe size.

## Hilti AG, Pipe Hangers

Product Designation	Hanger Rod Size, mm	Component Description	Nominal Pipe Sizes, mm
MAB-M10	10	Beam Clamp	20 through 100 mm
MAB-10	10	Beam Clamp	20 through 100 mm
MAB-M12	12	Beam Clamp	20 through 200 mm
MAB-13	12	Beam Clamp	20 through 200 mm
MAB-M16	16	Beam Clamp	20 through 300 mm
MAB-17	16	Beam Clamp	20 through 300 mm *
MQT-G M10	10	Swivel Beam Clamp	20 through 100 mm

Product Designation	Hanger Rod Size, mm	Component Description	For Nominal Pipe Sizes, in.
MP-MS 3/4	 M10	Pipe Clamp Ring	3/4 in.
MP-MS 1	M10	Pipe Clamp Ring	1 in.
MP-MS 1-1/4	M10	Pipe Clamp Ring	1-1/4 in.
MP-MS 1-1/2	M10	Pipe Clamp Ring	1-1/2 in.
MP-MS 2	M10	Pipe Clamp Ring	2 in.
MP-MS 54/57	M10	Pipe Clamp Ring	54/57 mm
MP-SPN	M10	Loop Hanger	3/4 in.
MP-SPN	M10	Loop Hanger	1 in.
MP-SPN	M10	Loop Hanger	1-1/4 in.
MP-SPN	M10	Loop Hanger	1-1/2 in.
MP-SPN	M10	Loop Hanger	2 in.
MP-SPN	M10	Loop Hanger	2-1/2 in.
MP-SPN	M10	Loop Hanger	3 in.
MP-SPN	M10	Loop Hanger	4 in.
MP-SPN	M12	Loop Hanger	133 mm
MP-SPN	M12	Loop Hanger	5 in.
MP-SPN	M12	Loop Hanger	159 mm
MP-SPN	M12	Loop Hanger	6 in.
MP-SPN	M16	Loop Hanger	219.1 mm



Product Designation	Hanger Rod Size, in. NC	Component Description	For Nominal Pipe Size, in.
MP-MX 125	M16	Pipe Ring	125 mm
		Clamp	
MP-MX 133	M16	Pipe Ring Clamp	133 mm
MP-MX 5"	M16	Pipe Ring Clamp	5 in.
MP-MX 159	M16	Pipe Ring Clamp	159 mm
MP-MX 6"	M16	Pipe Ring Clamp	6 in.

Product Designation	Hanger Rod Size, inch (metric)	Component Description	For Nominal Pipe Size, in.
LH	3/8 (M10)	Loop Hanger	3/4 through 4
LH	1/2 (M12)	Loop Hanger	6 and 8
SDC EG	1/2 (M12)	Clevis Hanger	2-1/2 and 3
SDC EG	5/8 (M16)	Clevis Hanger	4 and 5
SDC EG	3/4 (M20)	Clevis Hanger	6 and 8

Product Designation	Hanger Rod Size, in. (mm)	Component Description	For Nominal Pipe Size, in.
SLC-EG	3/8 (M10)	Clevis Hanger	2 and 2-1/2
SLC-EG	1/2 (M12)	"	3
SLC-EG	5/8 (M16)	"	4 and 5
SLC-EG	3/4 (M20)	"	6 and 8



Company Name:	Hilti AG
Company Address:	Feldkircherstrasse 100, Box 333, 9494 Schaan, Liechtenstein
Company Website:	http://hilti.com
New/Updated Product Listing:	No
Listing Country:	Liechtenstein
Certification Type:	FM Approved
Primary Class of Work:	1951-Pipe hangers For AS Sys



## **Pipe Hangers**

Pipe hangers are used to support a sprinkler piping system from the building structure. Two or more listed components may be required to form a complete hanger. The specific components required depend upon the type of building construction and the pipe size.

## Hilti Inc, Pipe Hangers

Product Designation	Hanger Rod Size, mm	<i>Component Description</i>	For Nominal Pipe Size, in.
MP-SP	10	Loop Hanger	3⁄4 through 4
	12	"	133 mm through 6
	16	"	219 mm
MP-MS	10	Pipe Clamp Hanger	68/72 through 4
MP-MS2	12	"	133 mm through 6
	16	"	219 mm
MF-SKD-M10	10	Toggle	3⁄4 through 1 1⁄2
MF-TSH-M10	10	Suspension Hanger	3⁄4 through 2
LH 3⁄4	3⁄8	Loop Hanger	3⁄4
LH 1	3⁄8	"	1
LH 1 1⁄4	3⁄8	"	1 1⁄4
LH 1-1/2	3⁄8	"	1 1⁄2
LH 2	3⁄8	"	2
LH 2 1⁄2	3⁄8	"	2 1⁄2
LH 3	3⁄8	"	3
LH 4	3⁄8	"	4
LH 6	1⁄2	"	6
LH 8	1⁄2	"	8
BC-WM 3⁄8	3⁄8	Beam Clamp	3⁄4 through 4
BC-WM 1/2	1⁄2	"	3⁄4 through 8
BC 3⁄8	3⁄8	Beam Clamp	3⁄4 through 4
BC 1/2	1⁄2	"	3⁄4 through 8
SDC-EG 2 1⁄2	1⁄2	Clevis Hanger	2 1/2
SDC-EG 3	1⁄2	"	3
SDC-EG 4	5⁄8	"	4
SDC-EG 5	5⁄8	"	5



SDC-EG 6	3⁄4	6
SDC-EG 8	3⁄4	8
		Metric only or English only or Primary/secondary

Product Designation	Hanger Rod Size, mm	<i>Component</i> <i>Description</i>	For Nominal Pipe Size, in.
00257366	3⁄8 (10)	Beam Clamp	3⁄4 through 4
00306600	3⁄8 (10)	Beam Clamp	3⁄4 through 4
00257367	1⁄2 (12)	Beam Clamp	5 through 8
00306601	1⁄2 (12)	Beam Clamp	5 through 8
00306602	3⁄8 (10)	Beam Clamp	3⁄4 through 4
00306603	1⁄2 (12)	Beam Clamp	5 through 8

Company Name:	Hilti Inc.
Company Address:	7250 Dallas Pkwy, Legacy Tower, Suite 1000, Plano, Texas 75024, USA
Company Website:	http://hilti.com
New/Updated Product Listing:	No
Listing Country:	United States of America
Certification Type:	FM Approved
Primary Class of Work:	1951-Pipe hangers For AS Sys